

## **IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

### **City of St. Anthony Has Experienced a Drinking Water Violation**

Our water system recently violated a drinking water standard. As our customers, you have a right to know what happened and what we did to correct the situation.

Both of our city pumps quit due to a power spike, which caused a loss of system pressure.

#### **What should I do?**

- ***You should have an alternative (e.g., bottled) water supply if this should happen in the future.***
- ***After the system is pressured back up flush water from the house by turning on all faucets for 15 minutes before drinking.***
- If you have specific health concerns, consult your doctor.

#### **What does this mean?**

This is not an immediate risk.

Bacteria and other contaminants could have entered the water system.

This is not an emergency. If it had been, you would have been notified immediately.

#### **What is being done?**

We continue to chlorinate the water and test it regularly.

We took samples on April 13, 2009 and sent them to the lab.

The lab reported on April 16, 2009 there are no traces of Coliforms or E-Coli.

We resolved the problem on April 13, 2009.

For more information, please contact Kirk/Kathy at (208) 624-3494 or 420 N Bridge St. Anthony, ID 83445.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by City of St. Anthony. State Water System ID#: 7220067.  
Date distributed: 4/28/2009.