

## **IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

### **City of St. Anthony Has Experienced a Drinking Water Violation**

Our water system violated a drinking water standard the morning of September 2, 2009. As our customers, you have a right to know what happened and what we did to correct the situation.

Both of our city pumps quit due to a circuit breaker tripping and operator error, which caused a loss of system pressure.

#### **What should I do?**

- ***You should have an alternative (e.g., bottled) water supply if this should happen in the future.***
- ***After the system is pressured back up flush water from the house by turning on all faucets for 15 minutes before drinking.***
- If you have specific health concerns, consult your doctor.

#### **What does this mean?**

This is not an immediate risk.

Bacteria and other contaminants could have entered the water system.

This is not an emergency. If it had been, you would have been notified immediately.

#### **What is being done?**

We continue to chlorinate the water and test it regularly.

We resolved the problem on the same day.

For more information, please contact City Hall at (208) 624-3494 or 420 N Bridge St. Anthony, ID 83445.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by City of St. Anthony. State Water System ID#: 7220067.  
Date distributed: 09/02/2009.